

APPENDIX - XIII

P.H.C. Khadakwasla
Tal - Haveli, Dist. Pune

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION

CERTIFICATE

No. 42/2024

Date: 29/02/24

It is certified that an inspection team headed by Dr. Shabde
Shirpurkar medical officer from Government Health Department Khadakwasla Pune Maharashtra 411024 inspected the Pawar Public School, Nanded City, Sinhagad Road, Pune, Maharashtra 411041 on 29/02/24 and found that the Pawar Public School has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year

Signature with Seal: _____

Shabde
Medical Officer
P.H.C. Khadakwasla
Tal. Haveli, Dist. Pune


Name: Dr. Shabde Shirpurkar

Designation: medical officer

To
Pawar Public School,
Nanded City, Sinhagad Road,
Pune Maharashtra 411041

Anjali Gurjar
Dr. Anjali Gurjar
Principal

PAWAR PUBLIC SCHOOL NANDED CITY
Sinhagad Road, Pune 411041





GOVT. OF MAHARASHTRA

**DEPUTY DIRECTOR, HEALTH SERVICES
STATE PUBLIC HEALTH LABORATORY, PUNE.
Near St. Mary School And Church, Pune 411001**



Telephone - Office :- (020) 263300225 Ext. 223

Email : statehealthlab@gmail.com

HEALTH SERVICES

NO. SPHL PUNE /Desk -79 / 1373 / 2024. DATE :- 23/01/2024.

Report on Chemical Analysis of Water

Sent by :- Pawar Public School, Nanded City, Nilesh Pawar, S.No. 24, Sinhgad road, Nanded City Pune- 411009.

With Ref. letter No :- ----

Dated :- 10/01 /2024

Date of Collection :- ----

Date of Receipt :- 10/01 /2024

Date of Examination :- 12/ 01 /2024 Onwards

(All the Analytical Results are in mg. / Lit. except pH , Turbidity.)

SR. NO	TEST PARAMETER	(P-21) Water	BIS Specifications 10500 : 2012 Normal Values	
			Desirable limit	Permissible limit
1	Physical Appearance	Clear	---	---
2	Odour	agreeable	agreeable	agreeable
3	Turbidity (as N.T.U.)	0.99	1.0	5.0
4	pH Value	7.65	6.5 to 8.5	No relaxation
5	Chlorides (as Cl)	7.32	250	1000
6	Nitrates (as No3)	0.065	45	No relaxation
7	Total Hardness (as Caco3)	34.20	200	600
8	Alkalinity (as Caco3)	34.58	200	600
9	Total Dissolved Solids	49.0	500	2000
10	Iron (as Fe)	ND	1.0	No relaxation
11	Fluoride (as F)	0.074	1.0	1.5

- ND :- Not detected.
- This report is restricted only for the sample /s submitted to this laboratory.
- It is presumed that the representative sample from the source is sent for analysis.
- This Sample /s is /are not collected by this laboratory.

Remark:- Above Sample No. -1 is chemically fit for drinking purpose on the basis of analysed parameters only.
However, this water source can be used for drinking purpose only after proper treatment, disinfection & ascertaining its bacteriological quality frequently or regularly.

Forwarded with compliments to:- Pawar Public School, Nanded City, Nilesh Pawar, S.No. 24, Sinhgad road, Nanded City Pune- 411009.




Fees	600 /-
Receipt No.	5115004
Date	10/01/2024



Dr. Anjali Gurjar
**Dr. Anjali Gurjar
Principal**

[Signature]
**Senior Scientific Officer
State Public Health Laboratory
Pune-411 001**

**PAWAR PUBLIC SCHOOL NANDED CITY
Sinhgad Road, Pune 411041**

	 MAHA GOVT Dy. Director of Health Services, STATE PUBLIC HEALTH LABORATORY, PUNE		
Dy Director tele No. Office Tele No.	26330509 (P) 26330225 (O) 26330223(Bact)	Cantonment water works campus, Near saint marry Church, Staveley road, Pulgate, camp Pune-411 001 (MH) INDIA Email ID : statehealthlab@gmail.com website : arogya.maharashtra.gov.in	
HEALTH SERVICES:	No.SPHPUNE/Desk-80/Bact.Section/water analysis report / 131 / 2024 Date : 18-1-2024		

-: Bacteriological Analysis Report of Water Samples :-


Sender's Name	Principal, Pawar Public School, S/No 28, Sinhgad Road, Nanded city Pune-411009
Sender's letter No. & date	----- / Dated 10/01/2024
Lab. Reference No.	74 / 396
Date of sample collection	10/01/2024
Date of sample received	10/01/2024
Analysis start date	10/01/2024

Sr. No	Sample Description	Analysis report			
		No. of bacteria found per 100 ml sample of water (As per IS 1055:2016)			
		Coliforms	Thermotolerent Bacteria	E.coli	Conclusion
1	Filter Water	00	00	00	FIT for drinking

Remark: Repeat the sample if found Unfit for drinking. And it can be used for drinking purpose, only after ascertaining it's bacteriological quality and found to be fit for drinking.

Note: This sample/s is/are not collected by this office or representative of this office.

सत्यमेव जयते



[Signature]

Dr. Anjali Gurjar
Principal

PAWAR PUBLIC SCHOOL NANDED CITY
Sinhgad Road, Pune 411041

[Signature]
Dongre RP

Senior Scientific Officer (Micro.)
State Public Health Laboratory
Pune-411 001

Analysis Fee Rs.340 /-
Receipt No. : 5115003
Date : 10/01/2024